

Attestation

CDPH CA01350

KHC Kwik-X

supplied by

Hilti Entwicklungsgesellschaft mbH

The joint sealant was received at Eurofins Product Testing A/S on 23 August 2021. The emissions were tested according to CDPH Section 01350. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 in the latest versions, see the test report no. 392-2021-00413602_H_EN.

Evaluation of the emission test result according to CDPH Section 01350 / CA01350

- No carcinogens and reproductive/developmental toxins could be detected.
- No individual compound exceeds one-half of the lowest concentrations of interest in a building (chronic REL).
- The requirements were passed both in reference to classrooms and office buildings.

The tested product complies with the requirements of the “Standard method for the testing and evaluation of volatile organic chemical emissions from indoor sources using environmental chambers (version 1.2)” as defined by the California Department of Public Health (CDPH) – Version of January 2017.

7 July 2022



Laura Hartung Sørensen
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager